


ENERG

енергия · ενεργεια

Y
IJA

IE
IA

HITACHI RAK-35RPE
RAC-35WPE


SEER 

A+++
A++
A+
A
B
C
D

←

A⁺⁺

kW 3,5
SEER 7,8
kWh/annum 157


SCOP 


A+++
A++
A+
A
B
C
D


←

A⁺⁺

kW X	2,6	X
SCOP X	4,9	X
kWh/annum X	742	X

 57 dB

 61 dB



ENERGIA · ЕНЕРГИЯ · ΕΝΕΡΓΕΙΑ · ENERGIJA · ENERGY · ENERGIE · ENERGI

626/2011


This label is edited by Hitachi's "ErP Active Tool". Ecodesign implementation, in accordance with Annex III of Regulation (EU) No 626/2011 of 4 May 2011, supplementing Directive 2010/30/Eu labeling of equipment air conditioning equipment.

SEER : seasonal performance of the equipment running in cooling mode; The highest is the value, the lowest will be the consumption. Regulation requires for any new product introduced in Europe since 01/01/2013 a minimum value of SEER of 3.6 (D class). **D**

For more precise information on seasonal performance of the equipment, refer to the values of SCOP and annual consumption (kWh/year).

Indoor Unit sound power level

Outdoor Unit sound power level



SCOP : seasonal energy performance of the equipment operating in heating mode; The higher is the value, the lowest will be the consumption. Regulation requires for any new product introduced in Europe since 01/01/2013 a minimum value of SCOP on average climate of 3.4 (A class). **A**

For more precise information on seasonal performance of the equipment, refer to the values of SCOP and annual consumption (kWh/year).

Climates defined by regulation	Lowest outdoor temperature	City used as reference	Heating period (hours/days)
Warm	+2° C	Athene	3590 h / 149 d
Average	-10° C	Strasbourg	4910 h / 204 d
Cold	-22° C	Helsinki	6646 h / 277 d

For heating operation, displayed informations related to the energy consumption are compulsory for average climate. Other climates are optional.